

ACOUSTIC TEST REPORT

BRIGHTER SMART HYBRID 480 PRO

Test conditions:

Test carried out according to ISO 3744:2011

Device tested:

Make: Brighter Lighting SP. Z O.O.

Model: Brighter Smart Hybrid 480 Pro

Setup:

The product was placed in anechoic chamber at IEN-BIP OL ITC (volume 350m³) in Łódź, Poland. The measurements were performed by IEN staff:

- mgr. inż. Kamil Wójciak
- mgr. inż. Patryk Gaj
- dr inż. Joanna Kopania

The product was allowed a minimum 20 minutes of warm-up time before measurements were performed

Test equipment list:


Type	Manufacturer	Serial number
Nor140	Norsonic	1407332
Nor1225	Norsonic	358181
Nor1209	Norsonic	21954
Nor1256	Norsonic	125626714
HD 9908T	Delta OHM	125626714
HD 2717T.D0	Delta OHM	11032846
30m	Richter	2134

Environment:

	Anechoic chamber	
Chamber volume	350	m ³
Measuring radius	1,00	m
Measurement surface area	6,3	m ²
10 log ₁₀ (s/s ₀)	8,0	-
Calibration of the measurement path	-25,7	dB
Temperature	16,6	°C
Humidity	52,3	%
Air pressure	987	hPa

Measurement method:

Measurements were performed using a setup with one microphone. The microphone was in turn moved to the measurement positions described below



A - measurement surface

B – reference box

Results:

The Smart Hybrid 480 Pro was measured in below 1 mode:

1. All effects static, Light source on, 100% output white light, Fan mode Auto

Measured sound pressure levels results are shown below:

Distance from fixture [m]	Fan Auto [dB]
LpA at 1m	43,2
LpA at 2m	37,2
LpA at 3m	33,7
LpA at 5m	29,2
LpA at 10m	23,2

The duration of the acoustical measurement for each position is 10s.